ADDENDUM # 2

DATE: May 12, 2022

BID NO.: 22-10

TITLE: REQUEST FOR PROPOSALS FOR CHESAPEAKE

MULTICULTURAL RESOURCE CENTER, RENOVATION, 331 E.

DOVER STREET, EASTON, MARYLAND

BY: Mary Kay Verdery, Grants Administrator

The following Addendum #2 is issued effective this date:

Specifications for beam to support interior opening. The beam to support the roof will need to be:

- 1. Beam: (3) 1.75" x 14" LVL
- 2. Columns: 3.5x5.25" PSL
- 3. End caps, both ends: Simpson Strong-Tie ECC64
- 4. Column Base: Simpson Strong-Tie CB46 (unless sitting on to pof 2X PT sole plate)
- 5. Footing (not at exterior wall): 24" x 24" x 12" D, w/3 #4 bars @ 9" OC each way.